



Certificate of Compliance

This certificate is issued for the following:

Polyethylene (PE) Pipe and Fittings for Underground Fire Protection Service

Product Description	Nominal Pipe Size (in.)	Rated Working Pressure	
		psi	(kPa)
DR11 Pipe	4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24	200	(1375)
DR9 Pipe	4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24	250	(1720)
DR7Pipe	4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24	335	(2305)

Prepared for:

JM Manufacturing Co., Inc. / dba JM Eagle Inc.
5200 West Century Blvd.
Los Angeles, CA 90045
USA

Manufacturing Facility:

JM Eagle Inc.
146 North Maple Ave
Hastings, NE 68902
USA

Approval Standard: FM 1613 (October 2022)

Approval Identification: PR458256

Approval Granted: March 21, 2023

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



Member of the FM Global Group

A handwritten signature in dark ink, appearing to read "D.B. Fuller".

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062

