

IAPMO RESEARCH AND TESTING, INC.

5001 E. Philadelphia Street, Ontario, CA 91761 • Phone (909) 472-4100 • Fax (909) 472-4244 • www.iapmort.org



CERTIFICATE OF LISTING



IAPMO Research and Testing, Inc. is a product certification body in which its product certification system includes inspection and testing of samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and/or warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

Issued To:

JM Eagle

5200 W CENTURY BLVD LOS ANGELES, CA 90045 , United States

Product:

Gas Meter Risers, Compression & Transition Fittings, Category 1

Products are in compliance with the following code(s):

Uniform Plumbing Code (UPC®)

Products are certified to the following standard(s)

ASTM F1924-2012

File Number: 4124

Effective Date: May 2019

Void After: May 2024*


Chairman, Product Certification Committee





Chief Technical Service Officer

*This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: JM Eagle

Effective Date: May 2019

File Number: 4124

Product: Gas Meter Risers, Compression & Transition
Fittings, Category 1

Void After: May 2024

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Identification:

Fittings shall be marked in such manner that it remains legible after installation and inspection with the manufacturer's name or trademark, "F1924", two or three letter coded plastic material identification in accordance with PPI TR-4 or equivalent, date or lot code identification, size followed by "IPS" or "CTS designation, SDR or wall thickness range, the word "Gas" or if the size does not permit "G", and "CAT1" or "CAT2

Fittings manufactured from materials listed in ASTM D2513 and intended for use with natural gas at elevated temperature greater than 73 F (23 C) shall be marked with additional code letters from table 4 of ASTM D2513. The first code letter to identify the temperature of the pressure rating, and the second code letter to identify HDB at the highest recommended pressure.


Characteristics:

Plastic mechanical fittings for use on outside diameter controlled polyethylene gas distribution pipe and tubing, nominal 2 pipe size (IPS) and smaller complying with ASTM D2513. To be installed in accordance with manufacturer's instruction and the latest edition of the Uniform Plumbing Code.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: JM Eagle

Effective Date: May 2019

File Number: 4124

Product: Gas Meter Risers, Compression & Transition
Fittings, Category 1

Void After: May 2024

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

Models

metfit Product Line

CAPS


Model Number	Description
605063000012	1/2" CTS .090 WALL
605063000072	1/2" CTS .062 WALL
605105000082	3/4" IPS 11.0
605113000002	1" CTS .090 WALL
605113000092	1" CTS .099 WALL
605138000082	1-1/4" CTS .090 WALL
605166000072	1-1/4" IPS
605238000082	2" IPS .216 WALL

COUPLINGS

Model Number	Description
600063063012	1/2" CTS .090 WALL
600063063072	1/2" CTS .062 WALL
600084084052	1/2" IPS .090 WALL
600105105082	3/4" IPS .095 WALL
600113113092	1" CTS .099 WALL SDR 11.5
600113113002	1" CTS .090 WALL SDR 12.5
600132132082	1" IPS .119 WALL
600138138082	1-1/4" CTS .090 WALL
601166166082	1-1/4" IPS .151 WALL 11.0
601166166072	1-1/4" IPS .166 WALL 10.0
601190190082	1-1/2" IPS .173 WALL 11.0
601238238082	2" IPS .216 WALL 11.0

IAPMO RESEARCH AND TESTING, INC.

CERTIFICATE OF LISTING



Issued To: JM Eagle

Effective Date: May 2019

File Number: 4124

Product: Gas Meter Risers, Compression & Transition
Fittings, Category 1

Void After: May 2024

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at pld.iapmo.org

90 DEGREE ELBOWS

Model Number	Description
602063063012	1/2" CTS .090 WALL
602105105082	3/4" IPS 11.0
602113113092	1" CTS .099 WALL SDR 11.5
602113113002	1" CTS .090 WALL SDR 12.5
602138138082	1-1/4" CTS .090 WALL

TEE'S

Model Number	Description
603063063012	1/2" CTS .090 WALL
603105105082	3/4" IPS SDR 11.0
603113113092	1" CTS .099 WALL
603113113002	1" CTS .090 WALL
603138138082	1-1/4" CTS .090 WALL

REDUCERS

Model Number	Description
604113063002	1" CTS .090 X 1/2" CTS .090
604105063002	3/4" IPS X 1/2" CTS .090
604113063012	1" CTS .099 X 1/2" CTS .090