



Certificate of Compliance

This certificate is issued for the following:

Polyethylene (PE) Pipe for Underground Fire Protection Service

<i>Product Designation</i>	<i>Nominal Pipe Size, in.</i>	<i>Pressure Rating, psi (kPa)</i>
IPS Class 200 Pipe	4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24	200 (1380)
IPS Class 250 Pipe	4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24	250 (1725)
IPS Class 335 Pipe	4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24	335 (2310)

Prepared for:

JM Manufacturing Co., Inc. / dba JM Eagle Inc.
5200 West Century Blvd.
Los Angeles, CA 90045
United States

Manufactured at:

JM Eagle Inc.
1820 South First Street
Sunnyside, WA 98944
United States

FM Approvals Class: 1613

Approval Identification: 0003055065

Approval Granted: October 13, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D. B. Fuller".

David Fuller
VP - Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group