

BOARD OF PUBLIC WORKS
MEMBERS

KEVIN JAMES
PRESIDENT

HEATHER MARIE REPENNING
VICE PRESIDENT

MICHAEL R. DAVIS
PRESIDENT PRO TEMPORE

JOEL F. JACINTO
COMMISSIONER

LUZ M. RIVAS
COMMISSIONER

FERNANDO CAMPOS
EXECUTIVE OFFICER

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
PUBLIC WORKS
BUREAU OF
ENGINEERING

GARY LEE MOORE, PE, ENV SP
CITY ENGINEER

1149 S. BROADWAY, SUITE 700
LOS ANGELES, CA 90015-2213

<http://eng.lacity.org>

September 13, 2017

Mai Huynh
Corp. Quality & Product Assurance Manager
JM Eagle
5200 W Century Blvd.
Los Angeles, CA 90045

SUBJECT: APPROVAL OF JM EAGLE SOLID WALL PVC PIPE

BR800079

Dear Mr. Huynh,

JM Eagle Solid Wall Polyvinyl Chloride (PVC) Pipe is approved for Citywide Use for gravity sanitary sewer and storm drain applications in the public right of way in sizes from 4" to 48". This approval letter supersedes the approval letter issued on June 29, 2017. This approval will expire on April 15, 2020. You may apply for a four year extension of this approval 120 days before it expires.

ASTM D 1784-11 Cell Class Classification: **12454**
Approved Pipe Size Range: **4 inches to 48 inches**
Minimum Initial Tensile Strength: **7,000 psi**
Minimum Initial Flexural Modulus: **400,000 psi**
Minimum Long (50-Year) Flexural Modulus: **120,000 psi**
Approved Extrusion Plant: **10990 Hemlock Ave, Fontana, CA 92337**
Joint Type: **Gasketed**

The City assumes no responsibility for any and all safety related issues in regards to the installation and use of this product. It is the responsibility of the installer to understand the appropriate use and limitations of this product and to address any and all safety concerns with the manufacturer. Further, it is the installer's responsibility to conform to all applicable industry and regulatory safety requirements.

Please be advised that you are required to report any change in the material composition of this product to the City immediately and to recertify this product prior to the expiration of this approval.

Please also maintain a copy of this approval for your records and distribute a copy of this approval to the Contractor or other users for use in the field. If you have any questions please contact Mr. Kent Welling (213) 485-5405.

Sincerely,

Edward Arrington, S.E., ENV SP
Engineer of Design
Wastewater Conveyance Engineering Division

