Ultra Blue Seismic PVCO | C909

SEISMIC RESISTANT BIAXIALLY ORIENTED PVC WATER PIPE



AWWA C909 ASTM D1784 Cell Class 12454 UL 1285, ANSI/NSF 61, ANSI/NSF 14 CSA B137.3.1

GASKETS: ASTM F714

JOINTS: ASTM D3139







M SEISMIC



POTABLE



SEWER



RECLAIM

DESCRIPTION





(Laying length tolerances are in accordance with AWWA and ASTM standards)

6" 8" 10" 12" 16" 24"

PIPE COLOR

BLUE


GREEN PURPLE

CIOD (AWWA C909)

305 psi

235 psi





Ultra Blue Seismic PVCO | C909

SEISMIC RESISTANT BIAXIALLY ORIENTED PVC WATER PIPE



SUBMITTAL AND DATA SHEET

CIOD (AWWA C909)

PIPE SIZE (IN)	AVG. O.D. (ID)	NOM. I.D. (IN)	MIN. T. (IN)	APPROX. E ¹	APPROX. E²	APPROX. D ⁹	APPROX. WGT (LBS/FT)
PRESSURE CLASS: 305 psi*							
6	6.90	6.30	0.284	8.25	9.25	8.755	3.969
8	9.05	8.26	0.373	9.75	10.75	11.170	6.879
10	11.10	10.13	0.457	10.00	11.00	13.697	10.358
12	13.20	12.05	0.544	12.50	13.50	16.037	14.764
16	17.40	15.85	0.717	11.50	12.50	19.600	25.550
24	25.80	23.57	1.063	16.25	17.25	33.050	57.613
PRESSURE CLASS: 235 psi*							
6	6.90	6.43	0.221	8.25	9.25	8.607	3.118
8	9.05	8.44	0.290	9.75	10.75	11.001	5.399
10	11.10	10.35	0.356	10.00	11.00	13.491	8.145
12	13.20	12.31	0.423	12.50	13.50	15.790	11.590
16	17.40	16.19	0.557	11.50	12.50	19.280	20.039
24	25.80	24.06	0.827	16.25	17.25	29.960	45.250

PRODUCT STANDARD

ANSI/AWWA C909

PIPE COMPOUND:

ASTM D1784 Cell Class 12454

INSTALLATION

JM Eagles™ Blue Brute/Big Blue /Ultra Blue Installation Guide

GASKET

ASTM F477

CERTIFICATION

ANSI/NSF 61 * NSF 14

* UL1285


CSA B137.3.1

20 feet

(Laying length tolerances are in accordance with AWWA and ASTM standards.)

NOMINAL LAYING LENGTH

Manning Coefficient (n) = 0.009 Hazen-Williams Coefficient (c) = 150



I.D. - Inside Diameter

O.D. - Outside Diameter

E - Distance between Assembly Marks and the end of the spigot.

T - Wall Thickness

D9 - Bell Outside Diameter











